



Montgomery County Government

Building and Codes Department

350 Pageant Lane, Suite 309

Clarksville, TN 37040

FIRE PUMP DESIGN INTENT 2007 NFPA 20, 2007 NFPA 13, and 2009 IBC & IFC To Accompany Architectural Review

Plans have been reviewed for compliance with the following:

- International Building Code (excluding Chapters 11 and 27), 2009 edition.
- International Plumbing Code, 2009 edition.
- International Fire Code, 2009 edition.
- International Mechanical Code, 2009 edition.
- International Fuel Gas Code, 2009 edition
- IECC International Energy Conservation Code, 2009 edition
- 2003 ICC/ANSI A117.1 Accessible & Useable Buildings & Facilities Code

Correction lists are not all inclusive.

Please Note: Items listed require correction by revised plans, addenda, field orders, or change orders before plans are approved for construction. Answers in letter form are *not* acceptable.

Starting construction before plans approval may be considered as just to issue a stop work order.

Architectural

1. The fire pump room must be separated from all other spaces of the building by 2 hour fire rated construction. The rating may be reduced to 1hour if the building is fully sprinklered with a NFPA 13 system. [NFPA 20 5.12.1.1]
2. Provide heat (NFPA 20 5.12.2), lighting (NFPA 20 5.12.3), emergency lighting (NFPA 20 5.12.4), ventilation (NFPA 20 5.12.5), and a floor drain in the pump room (NFPA 20 5.12.6).

Mechanical

1. Provide a plan and a cross section of the fire pump room. Identify any equipment that is not fire pump related (plumbing, mechanical, electrical, etc.). [2009 IFC Section 913 and NFPA 20 5.2.3]
2. Identify the fire pump manufacturer and model with pump and driver ratings. Identify the manufacturer of the controller and transfer switches (if applicable). [NFPA 20 5.7]
3. All controllers and transfer switches shall be specifically listed for electricmotor driven fire pump service. [NFPA 20 10.1.2.1]
4. Provide a fire pump system schematic showing all system components including valves, tamper switches, check valves, controllers, pumps, bypass, test header, suction and discharge line. If the system supplies standpipes and sprinklers, show all main system components on the schematic.
5. Provide a graph sheet showing the following information.
 - A. Water supply combined curve (i.e., separate fire pump curve, public water supply curve, and a third curve showing the combined pump and public water supply effect). [NFPA 13 Chapter 14, A.14.3.2, and Figures A.14.3.2(a) thru (d)]
 - B. Verify that pump operation does not reduce suction pressure head below allowable per NFPA 20 5.14.3. Include pressure losses from the backflow preventer and meter if needed.
 - C. Verify that the water supply is capable of delivering 150 percent of the pump's rated capacity. [NFPA 20 5.6.5]
6. Show the fire department connection. It must be on the discharge side of the fire pump. [NFPA 13 6.8]
7. Provide a pump bypass and a means to test the pump. [NFPA 20 5.14.4 and 5.19.1]
8. Provide a pressure relief valve. [NFPA 20 5.18]
9. Provide a jockey pump. [NFPA 20 5.24] Show check and control valves at the discharge piping, and a control valve at the suction piping. [NFPA 20 Figure A.5.24.4]
10. Each jockey and fire pump controller must have separate sensing lines and be located between the discharge check and control valves. [NFPA 20 10.5.2.1 and Figure A.10.5.2.1(a) & (b)] Show this on the plans and diagram/section.
11. For fire pumps in highrise buildings where electric motors are used and the height of the structure is beyond the pumping capability of fire department apparatus, a reliable emergency source of power shall be provided. [NFPA 20 9.2] For reliable sources, see NFPA 20 9.2.
12. Provide earthquake protection based on seismic design requirements. [NFPA 20 5.27]

13. Check valves and backflow prevention devices must be listed for fire protection service and when located upstream of the pump shall be located a minimum of ten pipe diameters from the pump suction flange. [NFPA 20 5.26.1, 5.26.3, and 5.14.3]

Electrical

1. Power for electric motor driven fire pumps must be from a reliable source or two or more independent sources. [NFPA 20 9.2]
2. Where multiple electric power sources are provided, they shall be arranged so that a fire at one source will not cause an interruption at the other source. [NFPA 20 9.2.5.1]
3. Where power is supplied by a service, it must be arranged to minimize the possibility of damage by fire. [NFPA 20 9.2.2 and .3] Service entrance conductors or fire pump feeder conductors must be physically routed outside the building and must be installed as service entrance conductors in compliance with NFPA 70, Article 230. When routed through or under the building, it must be encased in concrete at least 2" thick. [NFPA 20 9.1.3 and NFPA 70, Article 695.6(A), 230.6(1), or (2)]
4. The power supply feeding the fire pump and accessories must be dedicated, and directly connected with no disconnect device to the power source. [NFPA 20 9.2, 9.3, and A.9.3.2]
Except that a single disconnecting means and associated overcurrent protective device is permitted between a power source remote from the fire pump room and controller or transfer switch or listed combination of both. [NFPA 20 9.3.2.2.3.1] This disconnect must be supervised. [NFPA 20 9.3.2.2.3.2(E)]
5. Where alternate power is supplied by an onsite generator, the generator must be located and protected in accordance with 9.2.2 and Section 9.6. [NFPA 20 9.2.5.2]
6. All controllers must be located close to the motor with access for servicing. [NFPA 20 10.2.1]
7. Transfer of power to the fire pump controller between the normal supply and the alternate supply must take place within the fire pump room. [NFPA 20 9.6.4]
8. Manual transfer switches may *not* be used to transfer power to the fire pump controller. [NFPA 20 10.8.1.2]
9. A fire pump controller may not be used as a junction box to supply other equipment (jockey or makeup controllers). [NFPA 20 10.3.4.6]
10. No remote device may be installed that will prevent automatic operation of the transfer switch. [NFPA 20 10.8.1.3]
11. All pump room wiring must be in rigid, intermediate, or liquid tight flexible metal conduit, LFNCB, listed Type MC cable, Type MI cable, or other approved means. [NFPA 20 9.1.3 and NFPA 70, Article 695.6(E)]
12. If the pump is not constantly attended, the controller must have connections to provide an audible or visual alarm in a constantly attended location for the following conditions. [NFPA 20 10.4.7]

- A. Controller has operated into a motor running condition.
 - B. Loss of power to one of the phases on the line side of the motor contactor.
 - C. Phase reversal on the line side of the motor contactor.
 - D. Controller connected to alternate source where two sources of power are supplied.
13. Engine generator sets supplying emergency or standby power to fire pump assemblies shall be periodically tested accordance with NFPA 110. (IFC 913.5.2)